

SOUTH DELHI MUNICIPAL CORPORATION  
ENGINEERING DEPARTMENT



OFFICE OF THE EXECUTIVE ENGINEER (ELECT.)/CNZ  
UNDER SEVA NAGAR FLYOVER, BHISHAM PITAMAH MARG  
NEW DELHI


No.EEE-IV/2018-19/D- 32

dated 20/4/2018

In reference of Nit No.03 dated 16.04.18, for tender no.307388 & 307389, the item no.12 is by wrong type in the BOQ. The following amendments in item no.12 is as under:-

S.No.	Item No.12 in BOQ	Amendment in Item No.12
1	Supply, installation, testing and commissioning of electric driven terrace pump suitable for automatic operation and consisting of following: complete in all respect as required a) Horizontal type, multistage, centrifugal, spilt casing pump of cast iron body & bronze impeller with stainless steel shaft, mechanical seal and flow of 450 lpm at 40 m head confirming to IS:1520. b) 15 HP SQ cage induction motor TEFC type suitable for operation on 415 volts, 3 phase 50 Hz. AC with IP 55 class of protection for enclosure, horizontal foot mounted type with class-'F' insulation, confirming to IS-325. c) M.S fabricated common base fplate coupling, coupling gaurd, foundation bolts etc, as reqd. d) Suitable cement concrete foundation with anti vibration pads complete in all respect as reqd.	Supply, installation, testing and commissioning of electric driven terrace pump suitable for automatic operation and consisting of following: complete in all respect as required a) Horizontal type, multistage, centrifugal, spilt casing pump of cast iron body & bronze impeller with stainless steel shaft, mechanical seal and flow of 450 lpm at 40 m head confirming to IS:1520. b) <b>Suitable HP SQ cage induction motor</b> TEFC type suitable for operation on 415 volts, 3 phase 50 Hz. AC with IP 55 class of protection for enclosure, horizontal foot mounted type with class-'F' insulation, confirming to IS-325. c) M.S fabricated common base fplate coupling, coupling gaurd, foundation bolts etc, as reqd. d) Suitable cement concrete foundation with anti vibration pads complete in all respect as reqd.

Item No.12 may be read as the Amended item mentioned above.

  
Exe. Engr. (Elect.)/SZ

All the terms & condition of the NIT will be the same.

E.E. (Elect.)/IV/SZ  
S.D.M.C

~~SE(E)-II/SDMC~~

  
20/04/18  
V. K. RAWAT  
S.E. (ELECTRICAL)-II  
SOUTH DMC

AO/IT