



**SOUTH DELHI MUNICIPAL CORPORATION**  
**OFFICE OF THE E.E. (ELECT.)/Pr/WZ**  
Old zonal office building, Vishal Enclave Rajouri Garden  
New Delhi



Name of work: - Construction of Zonal Office Building at Shivaji place under West Zone(SDMC)

Subhead:-Supply, Installation, Testing and commissioning of HT Panel, Switchgear and Transformer in Electric Sub Station.

Subject: - Corrigendum for Tender No. 309316

S. No.	Item No.	Existing Provision	To be read as
1.	2	Transformer conforming to IS:2026(part-1 to part 5) insulation level 2 as per 1180	Transformer shall be supplied as per IS: 1180 and losses shall be as per energy efficiency level 2 of IS:1180
2.	4/5	Conforming to IS:1554(part-I)1988	The LT cable shall be as per IS:7098(part-I)1988 instead of IS:1554(part-I)1988

A. 1/8/2018  
EEE(Pr)/WZ

**E E Electric, Project**  
**West Zone, SDMC**